

Roll No: \_\_\_\_\_

JAYPEE UNIVERSITY OF INFORMATION TECHNOLOGY, WAKNAGHAT

TEST 3 EXAMINATION- Dec 2017

M.Tech 1<sup>st</sup> Semester

COURSE CODE: 14M31CE116

MAX. MARKS:35

COURSE NAME: Wastewater Treatment

COURSE CREDITS: 3

MAX. TIME: 2 Hrs

*Note: All questions are compulsory. Carrying of mobile phone during examinations will be treated as case of unfair means. Assume any other necessary data suitably.*

1. A staged RBC system is to be designed using following data:
  - a. Inflow = 50000 m<sup>3</sup>/d
  - b. Influent BOD = 500 mg/L
  - c. Influent soluble BOD = 300 mg/L
  - d. Desired effluent BOD = 20 mg/L
  - e. Desired effluent soluble BOD = 10 mg/L
  - f. Permissible organic loading : 4 – 10 g sBOD/m<sup>2</sup>.d  
8 – 20 g BOD/m<sup>2</sup>.d
  - g. Maximum 1<sup>st</sup> stage organic loading: 12-15 g sBOD/m<sup>2</sup>.d  
24 – 30 g BOD/m<sup>2</sup>.d
  - f. Disk surface area of standard unit: 9000 m<sup>2</sup> (7)
2. Write short notes on the following: (a) Advantages and disadvantages of stabilization pond (b) Aerobic and anaerobic oxidation pond (c) Advantages and disadvantages of anaerobic treatment (d) UASB (e) Sludge drying beds. (10)
3. Design a facultative stabilization pond to treat 5000 m<sup>3</sup>/d wastewater, BOD<sub>5</sub> 230 mg/l, from a town located in central India, latitude 22° N, elevation 100 m above sea level. The average temperature in January is 18° C. The effluent from the pond is to be used for irrigation. (6)
4. Design an upflow sludge blanket reactor for an average flow of 5 MLD of wastewater with the following data:
  - COD of wastewater = 400 mg/l
  - HRT = 6 hrs
  - Design COD loading = 1-2 kg COD/ m<sup>3</sup>.d
  - Velocity of rise of wastewater in the reactor through sludge bed = 0.75 hr
  - Velocity of wastewater in settling chamber = <1.5 m/hr
  - Flow area covered by each inlet = 1-2 m<sup>2</sup> (4)
5. Design sludge drying beds for digested sludge obtained from low rate anaerobic digesters for digesting a mixture of primary and excess activated sludge. The capacity of activated sludge plant is 50000 m<sup>3</sup>/d. Assume any other necessary data suitably. (4)
6. Design a bio-tower system to treat a wastewater flow of 50 MLD having settled BOD<sub>5</sub> equal to 3000 mg/l and to be operated at 25° C. The depth of media to be used is 6 m and the recirculation ratio is 2.5:1. The treatability constant at 20° C is 0.06 min<sup>-1</sup>.and desirable concentration of effluent BOD<sub>5</sub> is 20 mg/l. (4)